



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
3127453152

FOR OFFICE USE ONLY

Facility # 2046422
Permit # 00826-2017REM
Request Rec'd 07/12/2017
Amended Date
Approval Date 7/13/2017
Permit Expires 1/15/2018

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Commercial Building 2945 North Milwaukee Ave. Chicago, IL 60618 Contact: Grace Martinez (773) 520-2344	(2) <u>FACILITY</u> - name and address where tanks are located: Commercial Building 2945 North Milwaukee Ave. Chicago, IL 60618 Contact: Grace Martinez (773) 520-2344
--	--

(3) REMOVAL OF TANKS:

- (a) *Number and size of tanks being removed: (TK # 1) - 1,000*
- (b) *Description/location of piping being removed:*
- (c) *Product to be stored in each tank: (TK # 1) - #2 Fuel Oil*
- (d) *Reason of tanks being removed:*
- (e) *If tank(s) is leaking, indicate IEMA incident number:*
- (f) *Date each tank was last used: (TK # 1) - 12/31/1973*

- (4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) SPECIAL CONTINGENCIES :

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Midwest REM Enterprises, Inc.
2601 W. Lemoyne Street
Melrose Park, IL 60160

Contact Person: Timothy Lagousakos
Phone: (708) 345-8099
Contractor Registration # IL002379 Exp. 6/29/2019

Sincerely,


Chief Engineer-Storage Tank Section

Raul Valdivia

cc: Storage Tank Safety Specialist
Division File