



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 5012161
Permit # 00880-2017UPG
Request Rec'd 07/26/2017
Amended Date
Approval Date 7/26/2017 DS
Permit Expires 1/26/2018

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Chronister Oil Company 2026 Republic Springfield, IL 62702 Contact: Heather Hoffman (217) 523-5050 Ext. 1718	(2) <u>FACILITY</u> - name and address where tanks are located: Qik-N-EZ 1101 Stevenson Drive Springfield, IL 62703 Contact: Anne Needham (217) 529-0002
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 9) - 6,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 9) Piping - Flexible Double Wall A.P.T. Poly Tech S175SC, (TK # 9) Piping - Shear Valves, (TK # 9) Piping - Dispenser Sumps A.P.T. Poly Tech Polyethylene LM Series, (TK # 9) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 9) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 9) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 Plus*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.


- (5) **SPECIAL CONTINGENCIES** : Installing a poured 4' x 20' island with bollards. installing a new APT LMM-3617 poly dispenser sump for the new Gilbarco DEF/ Diesel Dispenser. The existing Diesel sump # 9 & 10 will become a transition sump & we will install new APT XP-175-SC DW Diesel piping from the transition sump to the new sump..Installing a 400 gallon above ground Kleer Blue DEF Tank. The existing & the new dispenser sumps will have new Veeder Root sump sensors (794380-208)

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Seneca Companies, Inc.
4140 East 14th Street PO Box 3360

Contact Person: Steve Cox
Phone: (816) 761-1270

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File