



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
3127453152

FOR OFFICE USE ONLY

Facility # 2010454
Permit # 00884-2017UPG
Request Rec'd 07/06/2017
Amended Date
Approval Date 7/27/2017
Permit Expires 1/29/2018

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Mohammad Iqbal 4070 N. Clark Street Chicago, IL 60613 Contact: Mohammad Ikram (773) 983-6285	(2) FACILITY - name and address where tanks are located: Home Run Gas and Mini Mart, LLC 4070 N. Clark Street Chicago, IL 60613 Contact: Mohammad Iqbal (773) 931-6295
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 7) - 4,000*
 - (b) Type of tanks:*
 - (c) Type of piping: (TK # 7) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX, (TK # 7) Piping - Shear Valves, (TK # 7) Piping - Valves Ball Valve, (TK # 7) Piping - Submersible Sumps Bravo B-400 Series, (TK # 7) Piping - Flex Connector Steel*
 - (d) Product to be stored in each tank: (TK # 7) - E-85*
 - (e) Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 7) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection Red Jacket FX2VD*
 - (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
 - (g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 7) Spill Contain Device - Manhole Pre-manufactured OPW 1-2100*
 - (h) Overfill prevention devices: (TK # 7) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO*
 - (i) Manway accessible at grade:*
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

BMPC, Inc.
1510 Spring Bay Road, Unit E
East Peoria, IL 61611

Contact Person: Amanda McCormick
Phone: (309) 208-5264
Contractor Registration # IL002393 Exp. 12/12/2018

Sincerely,



Chief Engineer-Storage Tank Section

Raul Valdivia

cc: Storage Tank Safety Specialist
Division File