



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 2046431
Permit # 00871-2017INS
Request Rec'd 07/24/2017
Amended Date 08/14/2017 DS
Approval Date 7/24/2017 DS
Permit Expires 1/24/2018

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Thorton Oil 10101 Linn Station Road Louisville, KY 40223 Contact: Stackhouse Brenda (502) 425-8022	(2) <u>FACILITY</u> - name and address where tanks are located: Thorntons Inc. Store 327 1136 24th Avenue Bellwood, IL 60104 Contact: Joe Zgonina (502) 572-1128
--	--

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed: (TK # 1) - 20,000, (TK # 2, 4) - 6,000, (TK # 3) - 10,000*
- (b) Type of tank(s): (TK # 1, 2, 3, 4) Tank - Fiberglass Brine Filled Double Wall Containment Solutions*
- (c) Type of piping: (TK # 1, 2, 3, 4) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX, (TK # 1, 2, 3, 4) Piping - Shear Valves, (TK # 1, 2, 3, 4) Piping - Valves Ball Valve, (TK # 1, 2, 3, 4) Piping - Submersible Sumps Containment Solutions Single Wall Fiberglass, (TK # 1, 2, 3, 4) Piping - Dispenser Sumps Bravo B-1000 Series, (TK # 1, 2, 3, 4) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 1, 4) - Gasoline, (TK # 2) - E-85, (TK # 3) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank: (TK # 1, 2, 3, 4) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 Plus with CSLD, (TK # 1, 2, 3, 4) Leak Detect - Tank - Hydrostatic Reservoir Sensors Interstitial Monitoring Veeder Root TLS 350 Dual stage*
 - Piping: (TK # 1, 2, 3, 4) Leak Detect - Piping - Electronic Pressurized Line Leak Detection Veeder Root TLS 350 PLLD leak sensors, (TK # 1, 2, 3, 4) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 Position sensitive sensor*
- (f) Corrosion Protection being used:*
 - Tank: (TK # 1, 2, 3, 4) Corrosion Prot - Tank - Fiberglass Non-Corrosive*
 - Piping: (TK # 1, 2, 3, 4) Corrosion Prot - Piping - Fiberglass Non-Corrosive*
- (g) Spill containment devices, piping and dispenser containment devices: (TK # 1, 2, 3, 4) Spill Contain Device - Pre-manufactured EBW 705 C1GKT Defender spill containment*
- (h) Overfill prevention devices: (TK # 1, 2, 3, 4) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO-410C overfill drop tube*

(4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov by calling (217)785-1020.

(5) GENERAL REQUIREMENTS : There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping

is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

(6) SPECIAL CONTINGENCIES :


I had entered the incorrect address. There also was a piping change. They had 3" piping heading to the islands. They changed it to 2" piping just added more pipe runs and slight reroute out of tank hole.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Anderson Pump Service, Inc.
19659 South 97th Avenue
Mokena, IL 60448

Contact Person: Ron Anderson
Phone: (708) 478-6190
Contractor Registration # IL002275 Exp. 5/21/2018

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File