



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 5032432
Permit # 00976-2017UPG
Request Rec'd 08/14/2017
Amended Date
Approval Date 8/14/2017 DS
Permit Expires 2/14/2018

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Casey's Retail Company 3305 SE Delaware Avenue P.O. Box 3001 Ankeny, IA 50021 Contact: Jill Reams-Widder (515) 965-6238	(2) <u>FACILITY</u> - name and address where tanks are located: Casey's General Stores, Inc. 301 West Quincy Street Griggsville, IL 62340 Contact: Jill Reams-Widder (515) 965-6238
---	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 1, 2) - 10,000

(b) Type of tanks:

(c) Type of piping:

(d) Product to be stored in each tank: (TK # 1, 2) - Gasoline

(e) Type of leak detection being used:

Tank:

Piping:

(f) Corrosion Protection being used:

Tank:

Piping:

(g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 1, 2) Spill Contain Device - Pre-manufactured EBW 705 C1GKT Defender spill containment

(h) Overfill prevention devices: (TK # 1, 2) Overfill Prev Device - Overfill Drop Tube Valve OPW 61SOP

(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.


(5) SPECIAL CONTINGENCIES : Installing new EBW 705 series 5 gallon spill containment & OPW 61SOP-412 overfill droptubes on tank ID # 1&2

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Seneca Companies, Inc.
4140 East 14th Street PO Box 3360
Des Moines, IA 50313

Contact Person: Steve Cox
Phone: (816) 761-1270
Contractor Registration # IL598 Exp. 2/23/2018

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File