



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2020330  
Permit # 01049-2017UPG  
Request Rec'd 08/23/2017  
Amended Date  
Approval Date 8/23/2017 DS  
Permit Expires 2/23/2018

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>North Suburban Petro Mart, Inc. 7760 North Nordica, Apt. 2-D Niles, IL 60714 Contact: Airaf Jahawala (312) 363-7120</p>	<p>(2) <b>FACILITY</b> - name and address where tanks are located:</p> <p>Arlington Heights Marathon 102 West Northwest Highway Arlington Heights, IL 60004 Contact: Jim Hussaini (312) 363-7120</p>
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 2) - 10,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 2) Piping - Submersible Sumps Bravo B-400 Series*
- (d) *Product to be stored in each tank: (TK # 2) - Gasoline*
- (e) *Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) *Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Tank 2 failed testing due to leaking riser on existing STP motor. Piping must be broken to make repair, requiring containment. Installing new sump and riser, using existing STP.

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Cardinal Compliance, LLC. 25850 S. Sunset Dr., Unit 2 Monee, IL 60449	Contact Person: Chris Derro Phone: (708) 452-8620 Contractor Registration # IL002418 Exp. 3/16/2019

Sincerely,



---

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File