



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2039752
Permit # 01051-2017UPG
Request Rec'd 08/23/2017
Amended Date
Approval Date 8/23/2017 DS
Permit Expires 2/23/2018

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Costco Wholesale Corporation P.O. Box 35005 Licensing / Legal Department Seattle, WA 981243405</p> <p>Contact: Dennis Bock (206) 313-8100</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Costco Gasoline Facility #381 7300 S. Cicero Avenue Bedford Park, IL 60501</p> <p>Contact: John Ellingsen (425) 251-6222</p>
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3) - 20,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 1, 2) Piping - Fiberglass Double Wall , (TK # 1, 2) Piping - Flexible Double Wall , (TK # 1, 2, 3) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 1, 2, 3) - Gasoline*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Replace existing E300 MPD's with 700S

Install new turbine in tank 2

Remove (1) turbine from tank 1- (currently (2) turbines in place, leaving (1)

Replace the existing flexible product siphon line between Tanks 1 and 2 with new fiberglass siphon line

NOTE: Sump sensors must be installed if none are present

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Jones Covey Group, Inc.
9595 Lucas Ranch Road #100
Rancho Cucamonga, CA 91730

Contact Person: Steve Sills
Phone: (909) 730-9185
Contractor Registration # IL002414 Exp. 10/8/2018

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File