



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 4009390  
Permit # 01139-2017REM  
Request Rec'd 09/13/2017  
Amended Date  
Approval Date 9/13/2017 DS  
Permit Expires 3/13/2018

**Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Osterbur Trucking Inc Box 26 219 W Main Royal, IL 61871</p> <p>Contact: Marvin Osterbur (217) 583-3145</p>	<p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Osterbur Trucking Inc 2704 County Rd 2200N Ogden, IL 61859</p> <p>Contact: Marvin Osterbur (217) 583-3145</p>
---	--

**(3) REMOVAL OF TANKS:**

- (a) *Number and size of tanks being removed: (TK # 1) - 10,000*
- (b) *Description/location of piping being removed:*
- (c) *Product to be stored in each tank: (TK # 1) - Diesel Fuel*
- (d) *Reason of tanks being removed:*
- (e) *If tank(s) is leaking, indicate IEMA incident number: 2017-0836*
- (f) *Date each tank was last used: (TK # 1) - Unknown*

- (4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

- (5) **SPECIAL CONTINGENCIES** : Remove, cut, and clean one (1) 10,000 UST (DIESEL) per incident #2017-0836

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Midwest Petroleum Service, LLC.  
23535 North 1530 East Road  
Danville, IL 61834

Contact Person: Mike Hall  
Phone: (217) 443-2263  
Contractor Registration # IL002306 Exp. 6/26/2018

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File