



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 1008411  
Permit # 01201-2017UPG  
Request Rec'd 09/27/2017  
Amended Date  
Approval Date 9/28/2017 DS  
Permit Expires 3/28/2018

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Illinois Dept. of Central Management Services 200 E. Ash Street Springfield, IL 62704</p> <p>Contact: Fearday Tom (217) 463-4215</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Dixon State Garage 819 Depot Avenue Dixon, IL 61021</p> <p>Contact: Ron Boyer (815) 284-5489</p>
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

*(a) Number and size of tanks being upgraded or repaired: (TK # 3, 4) - 10,000*

*(b) Type of tanks:*

*(c) Type of piping:*

*(d) Product to be stored in each tank: (TK # 3) - Diesel Fuel, (TK # 4) - Gasoline*

*(e) Type of leak detection being used:*

*Tank: (TK # 3, 4) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD, (TK # 3, 4) Leak Detect - Tank - Interstitial Monitoring Veeder Root TLS 450 Plus*

*Piping: (TK # 3, 4) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root 794380-208 Non-Discriminating Sump Sensor*

*(f) Corrosion Protection being used:*

*Tank:*

*Piping:*

*(g) Spill containment devices, piping, and dispenser containmnt devices:*

*(h) Overfill prevention devices:*

*(i) Manway accessible at grade:*

**(4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.


**(5) SPECIAL CONTINGENCIES** : Replace tank monitor system, install new Veeder-Root TLS-450 Plus with CSLD, 2 probes(846390-107), 2 interstitial sensors(794390-409), 4 sump sensors(794380-208). Installing new Franklin stand alone sump sensors. Stand alone sensors will be hard wired through a junction box to be able to shut down the submersible pump supplying that line upon detection of a leak

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Stenstrom Petroleum Services Group  
2422 Center Street

Contact Person: Nate Meyer  
Phone: (815) 398-6250

Sincerely,



Daniel G. Starks

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File