



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2019991
Permit # 01203-2017REM
Request Rec'd 09/28/2017
Amended Date
Approval Date 9/28/2017 DS
Permit Expires 3/28/2018

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Penske Truck Leasing Company LP Route 10 Green Hills P.O. Box 7635 Reading PA 196037635 Contact: Brian Yazemboski (610) 603-8450	(2) <u>FACILITY</u> - name and address where tanks are located: Penske Truck Leasing Company LP 3900 N. Mannheim Rd. Franklin Park, IL 601311273 Contact: Chuck (847) 671-3436
--	--

(3) **REMOVAL OF TANKS:**

- (a) *Number and size of tanks being removed: (TK # 4, 5, 6) - 12,000*
- (b) *Description/location of piping being removed:*
- (c) *Product to be stored in each tank: (TK # 4) - Gasoline, (TK # 5, 6) - Diesel Fuel*
- (d) *Reason of tanks being removed:*
- (e) *If tank(s) is leaking, indicate IEMA incident number:*
- (f) *Date each tank was last used: (TK # 4, 5, 6) - Unknown*

- (4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

- (5) **SPECIAL CONTINGENCIES** : Removal of UST's, piping and dispenser islands.

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Orivne, Inc.
55 East Monroe Street, Suite 3800
Chicago, IL 60603

Contact Person: Mike Leyden
Phone: (312) 656-2009
Contractor Registration # IL002408 Exp. 4/27/2019

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File