



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2007979  
Permit # 01224-2017UPG  
Request Rec'd 09/29/2017  
Amended Date  
Approval Date 10/3/2017 DS  
Permit Expires 4/3/2018

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>I-55 Truckstop Properties LLC 510 S. Bolingbrook Drive Bolingbrook, IL 60440</p> <p>Contact: John Puthusseril (630) 739-7006</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Greater Chicago Truck Plaza 510 South Bolingbrook Drive Bolingbrook, IL 60440</p> <p>Contact: Jeremy Smith (630) 739-7006</p>
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**

(a) *Number and size of tanks being upgraded or repaired: (TK # 13, 14) - 20,000, (TK # 17) - 12,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 13, 14, 17) Piping - Flexible Double Wall A.P.T. Poly Tech P175SC from dispenser to dispenser as shown in site plan, (TK # 13, 14, 17) Piping - Flexible Double Wall A.P.T. Poly Tech P200SC from tanks to master dispensers, (TK # 13, 14, 17) Piping - Chase Secondary Containment A.P.T. Poly Tech DCT-400, (TK # 13, 14, 17) Piping - Shear Valves, (TK # 13, 14, 17) Piping - Valves Ball Valve, (TK # 13, 14, 17) Piping - Submersible Sumps Bravo B-400 Series, (TK # 13, 14, 17) Piping - Flex Connector Steel*

(d) *Product to be stored in each tank: (TK # 13, 14) - Diesel Fuel, (TK # 17) - Bio-Diesel*

(e) *Type of leak detection being used:*

*Tank: (TK # 13, 14, 17) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 Plus with CSLD*

*Piping: (TK # 13, 14, 17) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection FE Petro STP-MLD-D, (TK # 13, 14, 17) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root 794380-208 Non-Discriminating Sump Sensor in all submersible and dispenser sumps*

(f) *Corrosion Protection being used:*

*Tank:*

*Piping:*

(g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 13, 14, 17) Spill Contain Device - Manhole Pre-manufactured OPW 1-2100*

(h) *Overfill prevention devices: (TK # 13, 14, 17) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Remove existing total containment pipe and replace with APT flexible most to be pulled out and repulled via existing chase piping Please see attached site drawing

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

BMPC, Inc.  
1510 Spring Bay Road, Unit E  
East Peoria, IL 61611

Contact Person: Amanda McCormick  
Phone: (309) 208-5264  
Contractor Registration # IL002393 Exp. 12/12/2018

Sincerely,

A handwritten signature in cursive script, reading "Daniel G. Starks", is written over a horizontal line.

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File