



City of Chicago
Department of Public Health
 333 South State Street, Room 200
 Chicago, IL 60604
 3127453152

<p>FOR OFFICE USE ONLY</p> <p>Facility # 2046499 Permit # 01261-2017REM Request Rec'd 10/10/2017 Amended Date Approval Date 10/10/2017 Permit Expires 4/10/2018</p>

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Augusta Condos, LLC 1363 Shermer Road Northbrook, IL 60062 Contact: Stan Bernshteyn (312) 434-4700</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>vacant building 1936 - 1938 West Augusta Blvd Chicago, IL 60622 Contact: Stan Bernshteyn (312) 434-4700</p>
---	--

(3) REMOVAL OF TANKS:

- (a) Number and size of tanks being removed: (TK # 1) - 1,000*
- (b) Description/location of piping being removed:*
- (c) Product to be stored in each tank: (TK # 1) - Gasoline*
- (d) Reason of tanks being removed:*
- (e) If tank(s) is leaking, indicate IEMA incident number:*
- (f) Date each tank was last used: (TK # 1) - 12/31/1973*

(4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) SPECIAL CONTINGENCIES :

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
<p>Tsarpalas Enterprises, Inc. 17494 West Hickory Lane Grayslake, IL 60030</p>	<p>Contact Person: Steve A Tsarpalas Phone: (847) 816-8828 Contractor Registration # IL297 Exp. 5/10/2018</p>

Sincerely,



Chief Engineer-Storage Tank Section

Raul Valdivia

cc: Storage Tank Safety Specialist
 Division File