



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 5009492
Permit # 01319-2017UPG
Request Rec'd 10/23/2017
Amended Date
Approval Date 10/23/2017 DS
Permit Expires 4/24/2018

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: GPM Investments, LLC 8565 Magellan Pkwy, Suite 400 Richmond, VA 23227 Contact: Rolfe Lann (804) 730-1568	(2) <u>FACILITY</u> - name and address where tanks are located: Jiffi Stop #580 3300 East Clear Lake Ave. Springfield, IL 62702 Contact: Rolfe Lann (804) 730-1568
--	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 1, 3) - 10,000, (TK # 6) - 15,000

(b) Type of tanks:

(c) Type of piping:

(d) Product to be stored in each tank: (TK # 1, 6) - Gasoline, (TK # 3) - Diesel Fuel

(e) Type of leak detection being used:

Tank: (TK # 1, 3, 6) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD

Piping: (TK # 1, 3, 6) Leak Detect - Piping - Electronic Pressurized Line Leak Detection Veeder Root TLS 450 Plus 8590 DPLLD

(f) Corrosion Protection being used:

Tank:

Piping:

(g) Spill containment devices, piping, and dispenser containment devices:

(h) Overfill prevention devices:

(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES : Upgrade ATG to TLS450 Plus and change out all probes and digital sensors.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

JF Acquisition, LLC d/b/a Jones & Frank
1330 St. Mary's Street, Ste. 210
Raleigh, NC 27605

Contact Person: Janice Marshall-Owens
Phone: (919) 987-1066
Contractor Registration # IL002422 Exp. 6/5/2019

Sincerely,

Daniel G. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File