



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 4016150
Permit # 01322-2017UPG
Request Rec'd 10/23/2017
Amended Date
Approval Date 10/23/2017 DS
Permit Expires 4/24/2018

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>ADM Trucking 2501 North Brush College Road Decatur, IL 62525 Contact: Mike Adams (217) 451-2660</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>ADM Trucking 2501 North Brush College Road Decatur, IL 62525 Contact: Mike Adams (217) 451-2660</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 6, 7) - 20,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 6, 7) Piping - Flexible Double Wall A.P.T. Poly Tech S200SC, (TK # 6, 7) Piping - Shear Valves, (TK # 6, 7) Piping - Valves Ball Valve, (TK # 6, 7) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 6, 7) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Removing the existing dispensers, islands, disp. containment sumps & fiberglass DW piping

Installing (4) APT LMM-3617DEF poly dispenser sumps w/ OPW single poppet sheer valves & steel flex connectors. Installing new APT XP-200-SC flex piping. Piping is manifolded in the Tank containment sump. Installing (4) Gilbarco Encore 700S Ultra High diesel / Def / satalite dispensers.

installing Veeder Root discriminating sump sensors in the dispenser & tank containment sumps.

Installing (4) 3' x 8' sloped concrete islands located 6' from the existing islands.


Site has existing sensors

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Seneca Companies, Inc.
4140 East 14th Street PO Box 3360
Des Moines, IA 50313

Contact Person: Steve Cox
Phone: (816) 761-1270
Contractor Registration # IL598 Exp. 2/23/2018

Sincerely,

A handwritten signature in cursive script, reading "Daniel S. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File