



**City of Chicago**  
**Department of Public Health**  
333 South State Street, Room 200  
Chicago, IL 60604  
3127453152

**FOR OFFICE USE ONLY**

Facility # 2003206  
Permit # 01327-2017INS  
Request Rec'd 10/23/2017  
Amended Date  
Approval Date 10/24/2017  
Permit Expires 4/24/2018

**Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Carmichael Leasing Co Inc 2200 S Loomis St Chicago, IL 60608</p> <p>Contact: Bill Steinert (312) 666-8500</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Carmichael Leasing Co., Inc. 2200 S. Loomis Street Chicago, IL 60608</p> <p>Contact: Bill Steinert (312) 666-8500</p>
--	--

**(3) INSTALLATION OF TANKS:**

- (a) Number and size of tanks being installed: (TK # 3) - 10,000, (TK # 4) - 6,000*
- (b) Type of tank(s): (TK # 3, 4) Tank - Fiberglass Double Wall Containment Solutions*
- (c) Type of piping: (TK # 3, 4) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX, (TK # 3) Piping - Shear Valves, (TK # 3, 4) Piping - Valves Ball Valve, (TK # 3, 4) Piping - Submersible Sumps Containment Solutions Single Wall Fiberglass, (TK # 3, 4) Piping - Flex Connector Steel, (TK # 4) Piping - Valves Foot Valve*
- (d) Product to be stored in each tank: (TK # 3) - Diesel Fuel, (TK # 4) - Gasoline*
- (e) Type of leak detection being used:*
  - Tank: (TK # 3, 4) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 300c, (TK # 3, 4) Leak Detect - Tank - Interstitial Monitoring Veeder Root TLS 300c*
  - Piping: (TK # 3) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection Red Jacket FX1D, (TK # 3) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 300c, (TK # 4) Leak Detect - Piping - European with No Test Req Suction*
- (f) Corrosion Protection being used:*
  - Tank: (TK # 3, 4) Corrosion Prot - Tank - Fiberglass Non-Corrosive*
  - Piping: (TK # 3, 4) Corrosion Prot - Piping - Fiberglass Non-Corrosive*
- (g) Spill containment devices, piping and dispenser containment devices: (TK # 3, 4) Spill Contain Device - Manhole Pre-manufactured OPW 1-2100-DEVR*
- (h) Overfill prevention devices: (TK # 3) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO, (TK # 4) Overfill Prev Device - Overfill Drop Tube Valve OPW 61SOP*

**(4)** The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) by calling (217)785-1020.

**(5) GENERAL REQUIREMENTS** : There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut

off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.


**(6) SPECIAL CONTINGENCIES :**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Accurate Tank Construction  
204 Poplar Place  
North Aurora, IL 60542

Contact Person: Jason Reed  
Phone: (630) 318-1813  
Contractor Registration # IL002360 Exp. 8/28/2018

Sincerely,



Chief Engineer-Storage Tank Section

Raul Valdivia

cc: Storage Tank Safety Specialist  
Division File