



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2010620
Permit # 01377-2017CAT
Request Rec'd 11/02/2017
Amended Date
Approval Date 11/3/2017 SB
Permit Expires 5/3/2018

Permit for INSTALLATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. A required job schedule for cathodic protection upgrade of underground storage tank(s) and piping must be submitted to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>TA Operating, LLC 24601 Center Ridge Road Suite 200 Westlake, OH 44145 Contact: Katie Wells (440) 808-3296</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Wilmington Minit Mart #609 809 E. Baltimore Street Wilmington, IL 60481 Contact: Kelli States (815) 476-2574</p>
--	--

(3) UPGRADE, OR REPAIR OF CATHODIC PROTECTION SYSTEM:

(a) Number and size of tanks having cathodic protection installed, upgraded, or repaired: (TK # 7, 8, 9) - 6,000

(b) Type of tanks:

(c) Type of piping:

(d) Product to be stored in each tank: (TK # 7, 8, 9) - Gasoline

(e) Type of leak detection being used:

Tank:

Piping:

(f) Corrosion Protection being used:

Tank:

Piping: (TK # 7, 8, 9) Corrosion Prot - Piping - Sacrificial Anode Flex Connector spike anode

(g) NACE certified designer:

(h) Method of integrity assessment of tank(s) being used:

(4) The owner must notify this Office when completion of cathodic protection upgrade has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for cathodic protection upgrade to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling 2177851020.

(5) SPECIAL CONTINGENCIES :

(6) The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(7) PERSON, FIRM OR COMPANY PERFORMING WORK:

Compliance Testing & Technology, Inc.
1142 North Adam PO Box 176
Mason, IL 62443

Contact Person: Greg Goeks
Phone: (866) 447-8144
Contractor Registration # IL002361 Exp. 7/24/2018

Sincerely,

A handwritten signature in dark ink that reads "Shelly Bradley". The script is cursive and fluid, with the first name "Shelly" and last name "Bradley" clearly distinguishable.

Shelly Bradley

cc: Storage Tank Safety Specialist
Division File