



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 4012903
Permit # 01435-2017ABN
Request Rec'd 10/02/2017
Amended Date
Approval Date 11/14/2017 DS
Permit Expires 5/15/2018

Permit for ABANDONMENT IN PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to abandon in place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>MPLX Terminals, LLC TT&R-HES&S 539 S. Main Street Findlay, OH 45840 Contact: W. Greg Moore (419) 421-3774</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>MPLX Terminals, LLC - Robinson Terminal 12345 East 1050th Avenue Robinson, IL 62454 Contact: Chris Peters (618) 544-3139</p>
---	--

(3) **ABANDONMENT IN PLACE OF TANKS:**

- (a) *Number and size tanks being abandoned: (TK # 6) - 6,000*
- (b) *Product stored in each tank: (TK # 6) - Diesel Fuel*
- (c) *Location of tanks being abandoned: CONTAMINATED SITE! IEMA Number: 2017-0937 The UST cannot be removed without potential damage to critical site infrastructure and endangering health and environment. The foundation of the overhead pipe and control line tray would be at risk of being undermined by excavation of the UST. Marathons piping diagrams indicate an active 4" trans mix line and a 1.25" additive product line that run along the East side of the UST. Utility locate shows a 12" storm sewer drain at a depth of eight feet immediately adjacent to the North end of the UST. The locate showed several additional lines and electrical lines which pass over the UST. The Marathon engineer also has spoken with Fred regarding this permit application.*
- (d) *Location of piping being abandoned: The piping cannot be removed without potential damage to critical site infrastructure and endangering health and environment. The foundation of the overhead pipe and control line tray would be at risk of being undermined by excavation of the UST and piping. Marathons piping diagrams indicate an active 4" trans mix line and a 1.25" additive product line that run along the East side of the UST. Utility locate shows a 12" storm sewer drain at a depth of eight feet immediately adjacent to the North end of the UST. The locate showed several additional lines and electrical lines which pass over the UST. The Marathon engineer also has spoken with Fred regarding this permit application.*

- (4) This permit is VOID if contamination is revealed during abandonment procedures or if tanks are not as indicated on your granted permit site plan. If contamination is revealed, this abandonment can continue only when the contaminated site section (2) of the certification on site condition has been submitted to our Office.

(5) **SPECIAL CONTINGENCIES :**

- (6) The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(7) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Bolin Enterprises, Inc.
506 North East 15th Street PO Box 70
Casey, IL 62420

Contact Person: Scott Justice
Phone: (217) 932-4533
Contractor Registration # IL002333 Exp. 10/10/2018

Sincerely,

Daniel G. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File