



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2044086  
Permit # 01446-2017UPG  
Request Rec'd 11/15/2017  
Amended Date  
Approval Date 11/16/2017 DS  
Permit Expires 11/28/2017

**Permit for Emergency Repair Request on 11/15/2017**

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>City of Lake Forest 800 N. Field Drive Lake Forest, IL 60045</p> <p>Contact: Dave DeMarco (847) 234-2600</p>	<p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>CLF Municipal Services Facility 800 N., Field Drive Lake Forest, IL 60045</p> <p>Contact: Dave DeMarco (847) 810-3576</p>
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1) - 20,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1) Piping - Shear Valves, (TK # 1) Piping - Flex Connector Steel*
- (d) *Product to be stored in each tank: (TK # 1) - Gasoline*
- (e) *Type of leak detection being used:*
- Tank:*
- Piping:*
- (f) *Corrosion Protection being used:*
- Tank:*
- Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

Found gasoline flex connector to be leaking under dispenser position #4.

- Remove existing flex connector and replace with new one
- install new double poppeted shear valve


**NOTE:** If there is no dispenser containment where piping is being broken a sump **MUST** be installed under a separate upgrade permit per 175.410 d)

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Accurate Tank Technologies, Inc.  
204 Poplar Place  
North Aurora, IL 60542

Contact Person: Tina McCorkle  
Phone: (630) 375-6121 Ext. 10  
Contractor Registration # IL1594 Exp. 8/15/2018

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a thin horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File