



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 4007178
Permit # 01471-2017UPG
Request Rec'd 11/17/2017
Amended Date
Approval Date 11/20/2017 DS
Permit Expires 5/22/2018

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Sumark Normal, LLC 409 S. Prospect, Suite F c/o Julia Davis Law Firm Bloomington, IL 61704 Contact: Julia Davis (309) 585-3536</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Mac's #1204 309 Landmark Drive Normal, IL 61761 Contact: Carrie Burtis (630) 942-5363</p>
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1, 2) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 1, 2) Piping - Valves Ball Valve, (TK # 1, 2) Piping - Submersible Sumps Franklin Fueling Systems A-4200 Series*
- (d) Product to be stored in each tank: (TK # 1, 2) - Gasoline*
- (e) Type of leak detection being used:*
 - Tank: (TK # 1, 2) Leak Detect - Tank - Interstitial Monitoring Veeder Root TLS 350*
 - Piping: (TK # 1, 2) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 1, 2) Spill Contain Device - Pre-manufactured EBW 705 C1GKT Defender spill containment*
- (h) Overfill prevention devices: (TK # 1, 2) Overfill Prev Device - Overfill Drop Tube Valve OPW 71-SO 4010 Overfill drop tube*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES** : After Tank Tech installs there stand alon system in tank 1&2 Seneca will install New Franklin Fueling 4200A series fiberglass tank sumps with new Red Jacket 1.5 hp submersibles, ball valves & Veeder Root sump sensors & tank interstitial sensors. Installing the existiing APT flex piping back into the new sumps . Insatalling EBW 705 series 5 gal spill & vapor spill containment manholes. Installing OPW 71SO-410 overfill droptubes.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:


Seneca Companies, Inc.

Contact Person: Steve Cox

4140 East 14th Street PO Box 3360
Des Moines, IA 50313

Phone: (816) 761-1270
Contractor Registration # IL598 Exp. 2/23/2018

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File