



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 7039136  
Permit # 01473-2017UPG  
Request Rec'd 11/17/2017  
Amended Date  
Approval Date 11/20/2017 DS  
Permit Expires 5/22/2018

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Acees, Inc. 5820 Cairo Road Paducah, KY 42001</p> <p>Contact: Gary Nathan Long (276) 443-6076</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Acees 510 Front Street Dongola, IL 62926</p> <p>Contact: Samantha Duty (618) 827-4836</p>
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 4, 5) - 12,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 4, 5) Piping - Fiberglass Single Wall Piping Ameron Dualoy 3000L single wall fiberglass piping, (TK # 4, 5) Piping - Shear Valves*
- (d) Product to be stored in each tank: (TK # 4, 5) - Gasoline*
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.


- (5) **SPECIAL CONTINGENCIES** : APT Dispenser sump LMM-3914-36-W No Sump sensor is required. Single wall piping **NOTE: NO sensors will be installed**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Mid-South Steel Products, Inc.  
2071 Corporate Circle Drive PO Box 277  
Cape Girardeau, MO 63703

Contact Person: Billy Thorne  
Phone: (573) 335-5529  
Contractor Registration # IL1194 Exp. 8/12/2018

Sincerely,

---

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File