



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Extended

FOR OFFICE USE ONLY

Facility # 2046393
Permit # 00608-2017INS
Request Rec'd 05/23/2017
Amended Date
Approval Date 5/30/2017 FS
Permit Expires 5/30/2018

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Penske Truck Leasing Company LP Route 10 Green Hills P.O. Box 7635 Reading PA 196037635 Contact: Brian Yazemboski (610) 775-6298	(2) <u>FACILITY</u> - name and address where tanks are located: Penske Truck # 6200-10 8500 W 68th Street Bedford Park, IL 60501 Contact: Drago Babich (847) 447-1240
--	---

(3) INSTALLATION OF TANKS:

- (a) *Number and size of tanks being installed: (TK # 1) - 20,000, (TK # 2) - 4,000, (TK # 3) - 2,000*
- (b) *Type of tank(s): (TK # 1, 2, 3) Tank - Fiberglass Double Wall Fluid Containment Brine Filled*
- (c) *Type of piping: (TK # 1, 2) Piping - Fiberglass Single Wall Piping Ameron Dualoy 3000L single wall fiberglass piping, (TK # 1, 2) Piping - Flexible Double Wall OPW Flexworks, (TK # 1, 2) Piping - Extractor Fitting Valves, (TK # 1, 2) Piping - Shear Valves, (TK # 1, 2) Piping - Valves Ball Valve, (TK # 1, 2, 3) Piping - Submersible Sumps Containment Solutions Single Wall Fiberglass, (TK # 1, 2, 3) Piping - Dispenser Sumps OPW FDS-4000 Series, (TK # 3) Piping - Fiberglass Double Wall Ameron Dualoy 3000/L, (TK # 3) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX, (TK # 3) Piping - Other submersible pump, (TK # 3) Piping - Flex Connector Steel*
- (d) *Product to be stored in each tank: (TK # 1) - Diesel Fuel, (TK # 2) - Gasoline, (TK # 3) - Diesel Exhaust Fluid (Non-Regulated)*
- (e) *Type of leak detection being used:*
- Tank: (TK # 1, 2, 3) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD, (TK # 1, 2, 3) Leak Detect - Tank - Hydrostatic Reservoir Sensors Interstitial Monitoring Veeder Root TLS 450 interstitial brine sensor, (TK # 3) Leak Detect - Tank - Non-Discriminating Sensors Interstitial Monitoring Veeder Root TLS 350 micro sensor*
- Piping: (TK # 1, 2) Leak Detect - Piping - Electronic Pressurized Line Leak Detection Veeder Root TLS 450 Plus 8590 DPLLD, (TK # 1, 2) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root 794380-208 Non-Discriminating Sump Sensor, (TK # 3) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection*
- (f) *Corrosion Protection being used:*
- Tank: (TK # 1, 2, 3) Corrosion Prot - Tank - Fiberglass Non-Corrosive*
- Piping: (TK # 1, 2) Corrosion Prot - Piping - Flexible Non-Corrosive, (TK # 3) Corrosion Prot - Piping - Fiberglass Non-Corrosive*
- (g) *Spill containment devices, piping and dispenser containment devices: (TK # 1, 2) Spill Contain Device - Manhole Pre-manufactured OPW 1C-3112D Edge Double Wall, (TK # 3) Spill Contain Device - Field Constructed*
- (h) *Overfill prevention devices: (TK # 1, 2, 3) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO-410C overfill drop tube*
- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov by calling (217)785-1020.
- (5) **GENERAL REQUIREMENTS** : There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in

diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

(6) SPECIAL CONTINGENCIES :

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

DRW Services, Inc.
600 East Joe Orr Road
Chicago Heights, IL 60411

Contact Person: Ray Kirchner
Phone: (708) 758-3222
Contractor Registration # IL194 Exp. 3/10/2018

Sincerely,

□

Fred Schneller

cc: Storage Tank Safety Specialist
Division File