



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 2022828
Permit # 01257-2017UPG
Request Rec'd 10/09/2017
Amended Date 11/27/2017 DS
Approval Date 10/10/2017 DS
Permit Expires 4/10/2018

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>V5 2010, Inc. 727 N. Harlem Ave. Oak Park, IL 60302 Contact: Zack Chacko (847) 361-1244</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Amoco 5311 727 North Harlem Avenue Oak Park, IL 60302 Contact: Paul Kapil (708) 386-2299</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 3, 4) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 3, 4) Piping - Fiberglass Single Wall Piping Ameron , (TK # 3, 4) Piping - Submersible Sumps Bravo B-400 Series*
- (d) Product to be stored in each tank: (TK # 3, 4) - Gasoline*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

revising new STP sump instalation due to steel pipe running to close to existing STP, moving sump location where probe is and moving probe to existing stp location doing this we have to extend product piping about 19 feet single wall we will send pictures if needed for clarification

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:


America Petropump Services LLC d/b/a Ampsco Services

Contact Person: Kiran Patibandla

4075 Fox Valley Center Dr., Unit 9
Aurora, IL 60504

Phone: (630) 649-8699
Contractor Registration # IL002420 Exp. 5/22/2019

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File