



Office of the Illinois State Fire Marshal  
 Division of Petroleum and Chemical Safety  
 1035 Stevenson Drive  
 Springfield, IL 62703  
 2177851020

**FOR OFFICE USE ONLY**  
 Facility # 2034916  
 Permit # 01500-2017UPG  
 Request Rec'd 11/29/2017  
 Amended Date  
 Approval Date 11/29/2017 DS  
 Permit Expires 12/12/2017

**Permit for Emergency Repair Request on 11/30/2017**

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Midwest Petroleum Development Company        7615 Route 14        Crystal Lake, IL 60014        Contact: Jayaprakash Reddy (815) 446-1197</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Citgo        7615 Route 14 @ Route 176        Crystal Lake, IL 60014        Contact: Jayaprakash Reddy (815) 446-1197</p>
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 4) - 10,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 4) Piping - Stainless Steel Single Wall Piping , (TK # 4) Piping - Steel Single Wall Piping*
- (d) *Product to be stored in each tank: (TK # 4) - Gasoline*
- (e) *Type of leak detection being used:*  
     *Tank:*  
     *Piping:*
- (f) *Corrosion Protection being used:*  
     *Tank:*  
     *Piping:*
- (g) *Spill containment devices, piping, and dispenser containmnt devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : The Premium submersible pump head is cracked at the piping connection and the entire submersible pump and the galvanized steel pipe nipples that connect the pump to the piping will be replaced. NOTE: All work to be done in existing sump, per contractor

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p>	
<p>B &amp; K Equipment Company        2939 175th Street        Lansing, IL 60438</p>	<p>Contact Person: Ed Angell        Phone: (708) 474-3344        Contractor Registration # IL1207 Exp. 2/14/2018</p>

---

Sincerely,

*Daniel G. Starks*

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File