



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2020577
Permit # 01505-2017UPG
Request Rec'd 11/27/2017
Amended Date
Approval Date 11/30/2017 DS
Permit Expires 5/30/2018

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Chase Products Company 2801 Gardner Road Broadview, IL 60155 Contact: Peter Chin (708) 273-1152	(2) FACILITY - name and address where tanks are located: Chase Products Company 2801 Gardner Road Broadview, IL 60155 Contact: Peter Chin (708) 273-1140
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 18, 19, 21) - 10,000, (TK # 22, 23) - 8,300*
- (b) Type of tanks:*
- (c) Type of piping:*
- (d) Product to be stored in each tank: (TK # 18, 22) - Acetone, (TK # 19, 21) - Hazardous Substance, (TK # 23) - Toluene*
- (e) Type of leak detection being used:*

Tank: (TK # 18, 19, 21, 22, 23) Leak Detect - Tank - Automatic Tank Gauging Incon TS-550 evo automatic tank gauge, (TK # 18, 19, 21, 22, 23) Leak Detect - Tank - Interstitial Monitoring Incon TSP ULS

Piping: (TK # 18, 19, 21, 22, 23) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Incon TSP ULS

- (f) Corrosion Protection being used:*

Tank:

Piping:

- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices: (TK # 18, 19, 21, 22, 23) Overfill Prev Device - Overfill Alarm Incon TS 550*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) SPECIAL CONTINGENCIES** : Installing Franklin Fueling EVO 550 console, probes and sensors to address OSFM NOV for installation / removal of systems with out proper certification or certified contractor.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

DRW Services, Inc.
600 East Joe Orr Road
Chicago Heights, IL 60411

Contact Person: Ray Kirchner
Phone: (708) 758-3222
Contractor Registration # IL194 Exp. 3/10/2018

Sincerely,

Daniel G. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File