



City of Chicago
Department of Public Health
 333 South State Street, Room 200
 Chicago, IL 60604
 3127453152

Amended

FOR OFFICE USE ONLY
 Facility # 2028177
 Permit # 00683-2017UPG
 Request Rec'd 06/05/2017
 Amended Date 12/04/2017 Chi
 Approval Date 6/13/2017
 Permit Expires 12/13/2017

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Commuter Rail Division of the Regional Transportation Authority 547 West Jackson Blvd. Chicago, IL 606615717</p> <p>Contact: Todd Cabanor (312) 322-6907</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Metra 14th Street - BN Zephyr 432 W. 14th Street Chicago, IL 60607</p> <p>Contact: Todd Cabanor (312) 322-6907</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 4) - 48,000, (TK # 9) - 2,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 4) Piping - Extractor Fitting Valves, (TK # 4) Piping - Shear Valves*
- (d) Product to be stored in each tank: (TK # 4, 9) - Diesel Fuel*
- (e) Type of leak detection being used:*
 Tank:
 Piping:
- (f) Corrosion Protection being used:*
 Tank:
 Piping:
- (g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 9) Spill Contain Device - Manhole Pre-manufactured OPW 1-2100C DEVR spill containment manhole*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

elevation did not allow a double wall spill bucket a opw 1-2100 5 gallon spill fill was replaced in stead of the double wall spill bucket

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
K-Plus Mechanical, Inc. 329 W. 18th St., Ste. 614 Chicago, IL 60616	Contact Person: Gerald Ford Phone: (815) 230-3040 Contractor Registration # IL002335 Exp. 2/9/2018

Sincerely,



Chief Engineer-Storage Tank Section

Raul Valdivia

cc: Storage Tank Safety Specialist
Division File