



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

<b>FOR OFFICE USE ONLY</b>
Facility # 2008503
Permit # 00057-2018UPG
Request Rec'd 01/16/2018
Amended Date
Approval Date 1/16/2018 DS
Permit Expires 7/17/2018

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>900 Arlington Heights, LLC 900 W. Euclid Arlington Heights, IL 60005</p> <p>Contact: Greg Kirtz (847) 452-4485</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Northwest Auto Wash 900 W. Euclid Arlington Heights, IL 60005</p> <p>Contact: Mark Olmsted (847) 259-1420</p>
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**


- (a) Number and size of tanks being upgraded or repaired: (TK # 5, 6, 7) - 8,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 5, 6, 7) Piping - Fiberglass Single Wall Piping Ameron Dualoy 3000L single wall fiberglass piping, (TK # 5, 6, 7) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 5, 6, 7) - Gasoline*
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Due to a leaking flex connector under dispenser #3/4, a dispenser containment sump will be installed at that dispenser position and new single wall fiberglass pipe connected to the existing single wall fiberglass pipe will be run into the the new sump which will contain a stainless steel flex connector connection to the dispenser.

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
<p>B &amp; K Equipment Company 2939 175th Street Lansing, IL 60438</p>	<p>Contact Person: Ed Angell Phone: (708) 474-3344</p>

Sincerely,

  
\_\_\_\_\_

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File