

## OFFICE OF THE ILLINOIS STATE FIRE MARSHAL Division of Technical Services

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

## FOR OFFICE USE ONLY

Facility # 1-039679
Permit # 02129-2008CAT
Request Rec'd 12/30/2008
Amended Date
Approval Date 12/30/2008
DS
Permit Expires 6/30/2009

## Permit for INSTALLATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. A required job schedule for cathodic protection upgrade of underground storage tank(s) and piping must be submitted to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE**.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
VP Oil, Inc. 1764 Illinois Street Roselle, IL 60172	Lakewood Mini - Mart 4742 East 2750 Road Sandwich, LaSalle Co., IL
Contact: Paul Unknown	Contact: Kathy or Sibi Unknown

## (3) <u>UPGRADE</u>, OR REPAIR OF CATHODIC PROTECTION SYSTEM:

- (a) Number and size of tanks having cathodic protection installed, upgraded, or repaired: (TK # 1) 12,000 gallons, (TK # 2) 8,000 gallons, (TK # 3) 4,000 gallons
- (b) Type of tanks:
- (c) Type of piping:
- (d) Product to be stored in each tank: (TK # 1, 2) Gasoline, (TK # 3) Diesel Fuel
- (e) Type of leak detection being used:

Tank:

Piping:

(f) Corrosion Protection being used:

Tank:

*Piping:* (TK # 1, 2, 3) - (Installing) Sacrificial Anode Cathodic Protection to all exposed steel and to flex connectors in all submersible sumps per N.O.V.

(g) NACE certified designer:

- Certification number:
- (h) Method of integrity assessment of tank(s) being used:
- (4) The owner must notify this Office when completion of cathodic protection upgrade has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for cathodic protection upgrade to the OSFM prior to the work being performed. Both forms can be obtained at <a href="https://www.state.il.us/osfm">www.state.il.us/osfm</a> or by calling (217)785-1020.
- (5) <u>SPECIAL CONTINGENCIES</u>:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Contact Person: Rick Warren Phone: (563) 344-0700

Caniel J. Starke

Contractor Registration # IL-2034 Exp.

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -Fire Department -Office Coordinator -Division File (Rev. - 1/98)