



Office of the Illinois State Fire Marshal
 Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 2177851020

FOR OFFICE USE ONLY
 Facility # 7023259
 Permit # 01039-2017INS
 Request Rec'd 08/14/2017
 Amended Date 02/01/2018 DS
 Approval Date 8/22/2017 DS
 Permit Expires 8/22/2018

Extended/Amended

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Omar Investment, Inc. 1123 East Walnut Carbondale, IL 62901 Contact: Hamad Omar (618) 306-5625</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Omar's 1123 East Walnut Carbondale, IL 62901 Contact: Ravinder Singh (618) 457-5192</p>
---	--

(3) INSTALLATION OF TANKS:

- (a) *Number and size of tanks being installed: (TK # 8) - 12,000, (TK # 9) - 7,000, (TK # 10) - 5,000*
- (b) *Type of tank(s): (TK # 8, 9, 10) Tank - Jacketed Steel Double Wall*
- (c) *Type of piping: (TK # 8, 9, 10) Piping - Fiberglass Single Wall Piping Ameron Dualoy 3000L single wall fiberglass piping, (TK # 8, 9, 10) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX, (TK # 8, 9, 10) Piping - Extractor Fitting Valves, (TK # 8, 9, 10) Piping - Shear Valves, (TK # 8, 9, 10) Piping - Valves Ball Valve, (TK # 8, 9, 10) Piping - Submersible Sumps OPW Flexworks Poly Sump, (TK # 8, 9, 10) Piping - Flex Connector Steel*
- (d) *Product to be stored in each tank: (TK # 8, 9) - Gasoline, (TK # 10) - Diesel Fuel*
- (e) *Type of leak detection being used:*
 - Tank: (TK # 8, 9, 10) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350, (TK # 8, 9, 10) Leak Detect - Tank - Interstitial Monitoring Veeder Root TLS 350*
 - Piping: (TK # 8, 9, 10) Leak Detect - Piping - Electronic Pressurized Line Leak Detection Veeder Root TLS 350, (TK # 8, 9, 10) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350*
- (f) *Corrosion Protection being used:*
 - Tank: (TK # 8, 9, 10) Corrosion Prot - Tank - Jacketed Steel Non-Corrosive*
 - Piping: (TK # 8, 9, 10) Corrosion Prot - Piping - Other dispenser containment sump, (TK # 8, 9, 10) Corrosion Prot - Piping - Fiberglass Non-Corrosive*
- (g) *Spill containment devices, piping and dispenser containment devices: (TK # 8, 9, 10) Spill Contain Device - Manhole Pre-manufactured OPW 1C-3101 Edge Spill containment manhole*
- (h) *Overflow prevention devices: (TK # 8, 9, 10) Overflow Prev Device - Overflow Drop Tube Valve OPW 71SO-410C overflow drop tube*

(4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov by calling (217)785-1020.

(5) **GENERAL REQUIREMENTS** : There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut

off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

(6) SPECIAL CONTINGENCIES :


Change of site layout, new drawing to be uploaded. Tanks locations have not changed, only minor change in layout of dispensers.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Neumayer Equipment Company, Inc.
5060 Arsenal Street
Saint Louis, MO 63139

Contact Person: Jimmy Spiros
Phone: (314) 772-4501
Contractor Registration # IL1502 Exp. 3/26/2018

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File