



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Extended

FOR OFFICE USE ONLY

Facility # 3035903
Permit # 01288-2017UPG
Request Rec'd 10/13/2017
Amended Date
Approval Date 10/16/2017 DS
Permit Expires 10/17/2018

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Mac's Convenience Stores, LLC 550 Warrenville Rd Suite 400 Lisle, IL 60532 Contact: Charlene Troyer (630) 800-6065</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Bigfoot #136 7815 North University Street Peoria, IL 61615 Contact: Kim Frame (812) 379-9227</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 2) - 12,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 2) Piping - Flexible Double Wall OPW Flexworks, (TK # 2) Piping - Shear Valves, (TK # 2) Piping - Valves Ball Valve, (TK # 2) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 2) - Gasoline*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) SPECIAL CONTINGENCIES** : Remove existing pipe between tank and 1st dispenser, install new pipe, flex connector, shear valve, and ball valve. Sumps and sensors are required if none are existing

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Neumayer Equipment Company, Inc.
5060 Arsenal Street
Saint Louis, MO 63139

Contact Person: Jimmy Spiros
Phone: (314) 772-4501
Contractor Registration # IL1502 Exp. 3/26/2018

Sincerely,

Daniel H. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File