



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 3000811
Permit # 00233-2018UPG
Request Rec'd 02/21/2018
Amended Date
Approval Date 3/1/2018 DS
Permit Expires 9/4/2018

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Blick & Blick Oil Inc 203 SE 5Th Ave Aledo, IL 61231</p> <p>Contact: Steve Blick (309) 582-2012</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Blick & Blick Oil Inc 203 S.E. 5Th Ave Aledo, IL 61231</p> <p>Contact: Steve Blick (309) 582-2012</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3, 4, 9) - 6,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 1, 2, 3, 4, 9) Piping - Flexible Double Wall A.P.T. Poly Tech from all existing tanks to new dispensers, (TK # 1, 2, 3, 4, 9) Piping - Shear Valves, (TK # 1, 2, 3, 4, 9) Piping - Valves Ball Valve, (TK # 1, 2, 3, 4, 9) Piping - Submersible Sumps Franklin Fueling Systems 4736 Series Polyethylene Single Wall*
- (d) Product to be stored in each tank: (TK # 1) - E-85, (TK # 2, 9) - Gasoline, (TK # 3, 4) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank: (TK # 1, 2, 3, 4, 9) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD*
 - Piping: (TK # 1, 2, 3, 4, 9) Leak Detect - Piping - Electronic Pressurized Line Leak Detection Veeder Root TLS 450 Plus 8590 DPLLD, (TK # 1, 2, 3, 4, 9) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 450 Plus in all new dispenser and submersible sumps*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 1, 2, 3, 4, 9) Spill Contain Device - Manhole Pre-manufactured Emco Wheaton A1004 Double Wall*
- (h) Overfill prevention devices: (TK # 1, 2, 3, 4, 9) Overfill Prev Device - Overfill Drop Tube Valve Emco Wheaton A1100 Guardian*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.


(5) **SPECIAL CONTINGENCIES** : Contractor is re-piping the entire site as well as installing new overfill and spill containment. Compatibility information for E85 tank is included in permit application

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Central Petroleum Equipment Company
109 Terrace Dr.
Blue Grass, IA 52726

Contact Person: Roger L Clark
Phone: (563) 381-5092
Contractor Registration # IL345 Exp. 6/12/2018

Sincerely,



Daniel G. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File