



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 1011910
Permit # 00254-2018UPG
Request Rec'd 03/02/2018
Amended Date
Approval Date 3/6/2018 DS
Permit Expires 9/6/2018

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Rockford Board of Education # 205 201 S. Madison Street Rockford, IL 611042092 Contact: Jim Kaplanes (815) 871-4563	(2) <u>FACILITY</u> - name and address where tanks are located: Board of Education Transportation Center 2000 Christina Street Rockford, IL 61104 Contact: Seth Schwirblat (815) 966-3789
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 9, 10) - 12,000, (TK # 11, 12, 13) - 1,000, (TK # 14, 15) - 550*
- (b) *Type of tanks:*
- (c) *Type of piping:*
- (d) *Product to be stored in each tank: (TK # 9, 10) - Ultra Low Sulfur Diesel, (TK # 11) - Automatic Transmission Fluid, (TK # 12, 14) - Lube Oil, (TK # 13) - Used Oil, (TK # 15) - Gear Lube*
- (e) *Type of leak detection being used:*
- Tank: (TK # 9, 10, 11, 12, 13, 14, 15) Leak Detect - Tank - Automatic Tank Gauging Incon TS 550 Evo*
- Piping:*
- (f) *Corrosion Protection being used:*
- Tank:*
- Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.


(5) SPECIAL CONTINGENCIES :

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Howard Lee & Sons Inc.
4093 Perryville Road PO Box 446
Cherry Valley, IL 61016

Contact Person: Vicky Buhl
Phone: (815) 332-4966
Contractor Registration # IL456 Exp. 3/20/2018

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File