



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 1015023
Permit # 00277-2018UPG
Request Rec'd 03/07/2018
Amended Date
Approval Date 3/12/2018 DS
Permit Expires 9/12/2018

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Kelley Williamson Company 1132 Harrison Avenue Rockford, IL 61104 Contact: Bob Sanders (815) 397-9410	(2) <u>FACILITY</u> - name and address where tanks are located: West Street Mobil 1111 South West Avenue Freeport, IL 61032 Contact: Valerie Poss (815) 397-9410
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 3) - 12,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 3) Piping - Fiberglass Single Wall Piping, (TK # 3) Piping - Valves Ball Valve, (TK # 3) Piping - Submersible Sumps OPW Fiberglass Single Wall, (TK # 3) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 3) - Gasoline*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 3) Leak Detect - Piping - Electronic Pressurized Line Leak Detection Veeder Root TLS 350 PLLD leak sensors*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES** : Remove concrete area and STP manhole on tank 3; excavate to top of tank and remove existing submersible turbine pump. Disconnect existing piping and install OPW Single wall STP sump. Install new FE Petro 2hp submersible turbine pump and tie onto existing single wall piping and install flex connector and ball valve.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:


Stenstrom Petroleum Services Group

Contact Person: Robert Stenstrom

2422 Center Street
Rockford, IL 61108

Phone: (815) 398-6250
Contractor Registration # IL1890 Exp. 3/7/2020

Sincerely,

A handwritten signature in cursive script that reads "Daniel H. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File