



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
3127453152

FOR OFFICE USE ONLY

Facility # 2036651
Permit # 00278-2018UPG
Request Rec'd 03/12/2018
Amended Date
Approval Date 3/12/2018
Permit Expires 9/12/2018

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Chicago Park District 541 North Fairbanks Court Chicago, IL 60611 Contact: Dan Cooper (312) 742-4287	(2) FACILITY - name and address where tanks are located: Burnham Park Harbor 1559 S Lake Shore Dr Chicago, IL 60605 Contact: Pam Meidel (312) 747-1335
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 2) - 12,000, (TK # 3) - 8,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 2) Piping - Flexible Double Wall A.P.T. Poly Tech MarinaFlex metallic ducted, (TK # 2) Piping - Transition Sumps Bravo B-830 Series Single Wall*
- (d) *Product to be stored in each tank: (TK # 2) - Gasoline, (TK # 3) - Diesel Fuel*
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 2, 3) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Petroleum Technologies Equipment, Inc.
8447 West 44th Place
Lyons, IL 60534

Contact Person: Thomas Doherty
Phone: (708) 426-0400
Contractor Registration # IL2051 Exp. 1/17/2020

Sincerely,



Chief Engineer-Storage Tank Section

Raul Valdivia

cc: Storage Tank Safety Specialist
Division File