



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2016399  
Permit # 00374-2018UPG  
Request Rec'd 03/28/2018  
Amended Date  
Approval Date 3/28/2018 DS  
Permit Expires 9/28/2018

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Eddie Bauer, LLC 800 Pasquinelli Dr. Westmont, IL 60559</p> <p>Contact: Andy Petkovsek (630) 321-4364</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Eddie Bauer, LLC 800 Pasquinelli Drive Westmont, IL 60559</p> <p>Contact: Eri Gomez (630) 947-5773</p>
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

*(a) Number and size of tanks being upgraded or repaired: (TK # 1) - 15,000*

*(b) Type of tanks:*

*(c) Type of piping: (TK # 1) Piping - Valves Foot Valve*

*(d) Product to be stored in each tank: (TK # 1) - Diesel Fuel*

*(e) Type of leak detection being used:*

*Tank:*

*Piping:*

*(f) Corrosion Protection being used:*

*Tank:*

*Piping:*

*(g) Spill containment devices, piping, and dispenser containment devices:*

*(h) Overfill prevention devices:*

*(i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

- provide mini excavator to remove top layer of rock and soil from over the tank plus excavate by hand to find suction pipe connection to the tank**
- Isolate the piping from the tank**
- perform air test on piping between the tank and the building just to confirm that the piping is leak free**
- If piping passes, install a new foot valve and suction stub in the tank**
- Install ball valves at the tank to allow for future isolation of the piping**
- Retest line to assure the new check valve is holding**


- **-Install a sleeve around the supply piping connection to the tank so it is accessible in the future**
- **-Install 42" manhole over pipe sleeve (No concrete pad included around the manhole**
- **-backfill excavation**
- **-Rough grade work area**
- **PER 175.410 a) a tank containment sump must be installed**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Accurate Tank Construction  
204 Poplar Place  
North Aurora, IL 60542

Contact Person: Jason Reed  
Phone: (630) 318-1813  
Contractor Registration # IL002360 Exp. 8/28/2018

Sincerely,

A handwritten signature in cursive script, reading "Daniel G. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File