



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
3127453152

FOR OFFICE USE ONLY

Facility # 2009036
Permit # 00415-2018INS
Request Rec'd 04/06/2018
Amended Date
Approval Date 4/9/2018
Permit Expires 10/10/2018

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Nemeh, Sue & Bill 7601 S. State Street Chicago, IL 60619 Contact: Bill Nemeh (708) 829-1060	(2) <u>FACILITY</u> - name and address where tanks are located: S & J Mobil, Inc. 7601 South State Chicago, IL 60619 Contact: Bill Nemeh (708) 829-1060
---	---

(3) INSTALLATION OF TANKS:

(a) Number and size of tanks being installed: (TK # 5) - 5,000

(b) Type of tank(s): (TK # 5) Tank - Fiberglass Double Wall XERXES

(c) Type of piping: (TK # 5) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX, (TK # 5) Piping - Extractor Fitting Valves, (TK # 5) Piping - Shear Valves, (TK # 5) Piping - Valves Ball Valve, (TK # 5) Piping - Submersible Sumps XERXES Fiberglass Single Wall, (TK # 5) Piping - Flex Connector Steel

(d) Product to be stored in each tank: (TK # 5) - E-85

(e) Type of leak detection being used:

Tank: (TK # 5) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD, (TK # 5) Leak Detect - Tank - Interstitial Monitoring Veeder Root TLS 350

Piping: (TK # 5) Leak Detect - Piping - Electronic Pressurized Line Leak Detection Veeder Root TLS 350 PLLD leak sensors, (TK # 5) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 Position sensitive sensor

(f) Corrosion Protection being used:

Tank: (TK # 5) Corrosion Prot - Tank - Fiberglass Non-Corrosive

Piping: (TK # 5) Corrosion Prot - Piping - Fiberglass Non-Corrosive

(g) Spill containment devices, piping and dispenser containment devices: (TK # 5) Spill Contain Device - Manhole Pre-manufactured OPW ISC-3112D Double Wall

(h) Overfill prevention devices: (TK # 5) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SOM

(4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov by calling (217)785-1020.

(5) GENERAL REQUIREMENTS : There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion

protection.


(6) SPECIAL CONTINGENCIES :

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Crowne Industries, Ltd.
651 S. Sutton Road #214
Streamwood, IL 60107

Contact Person: Robert Sumoski
Phone: (630) 497-9009
Contractor Registration # IL002345 Exp. 5/16/2018

Sincerely,



Chief Engineer-Storage Tank Section

Raul Valdivia

cc: Storage Tank Safety Specialist
Division File