



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 6029334
Permit # 00424-2018UPG
Request Rec'd 04/09/2018
Amended Date
Approval Date 4/9/2018 DS
Permit Expires 10/10/2018

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Midwest Petroleum Company 6760 Southwest Avenue Saint Louis, MO 63143 Contact: Jeff Ziegler (314) 647-5550 Ext. 505	(2) FACILITY - name and address where tanks are located: MPC #58 4001 South State Route 159 Glen Carbon, IL 62034 Contact: Chuck Keller (800) 747-3777
---	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 4) - 20,000

(b) Type of tanks:

(c) Type of piping:

(d) Product to be stored in each tank: (TK # 4) - Gasoline

(e) Type of leak detection being used:

Tank:

Piping:

(f) Corrosion Protection being used:

Tank:

Piping:

(g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 4) Spill Contain Device - Manhole Pre-manufactured OPW 1C-3112D Edge Double Wall

(h) Overfill prevention devices:

(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Parker Petroleum Sales and Service Inc.
1424 South Main Street
Troy, MO 63379

Contact Person: Philip R Parker
Phone: (636) 240-7777
Contractor Registration # IL2154 Exp. 5/19/2018

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File