



Office of the Illinois State Fire Marshal
 Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 2177851020

FOR OFFICE USE ONLY
 Facility # 5037374
 Permit # 00427-2018UPG
 Request Rec'd 04/10/2018
 Amended Date
 Approval Date 4/10/2018 DS
 Permit Expires 4/23/2018

Permit for Emergency Repair Request on 4/9/2018

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Quincy School District 172 1416 Maine Street Quincy, IL 62301 Contact: Shane Barnes (217) 224-5910</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Quincy School District 172 4400 Maine Street Quincy, IL 62301 Contact: Max Miller (217) 224-5910</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1) - 10,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1) Piping - Shear Valves*
- (d) *Product to be stored in each tank: (TK # 1) - Diesel Fuel*
- (e) *Type of leak detection being used:*
 Tank:
 Piping:
- (f) *Corrosion Protection being used:*
 Tank:
 Piping:
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : REPLACED 1 1/2" COUPLING UNDER THE SHEAR VALVE UNDER A EMERGENCY REPAIR IT WAS DRIPPING. **NOTE: If there is not an existing containment sump under dispenser where piping was broken, one must be installed under a separate upgrade permit per 175.410 d)**

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p>	
<p>R. L. Hoener Company 2923 Gardner Expressway P. O. Box 1086</p>	<p>Contact Person: Marty Jackson Phone: (217) 223-2190</p>

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File