



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 4040538
Permit # 00431-2018ENT
Request Rec'd 04/11/2018
Amended Date
Approval Date 4/11/2018 DS
Permit Expires 10/11/2018

Permit for HOTWORK / ENTRY into Underground Storage Tank(s) for Petroleum and Hazardous Substances.

Permission to enter underground storage tank(s) is hereby granted. Such tank entry shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Murphy Oil USA, Inc. 200 East Peach Street El Dorado, AR 71730</p> <p>Contact: Aaron Grieb (870) 677-6116</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Murphy USA #6708 1206 Ave of Mid America Effingham, IL 62401</p> <p>Contact: Stacy McWhorter (217) 342-3780</p>
--	--

(3) **ENTRY OF TANKS:**

(a) *Number and size of tanks being entered: (TK # 3) - 14,000, (TK # 4) - 7,000*

(b) *Type of tanks:*

(c) *Product to be stored in each tank: (TK # 3, 4) - Gasoline*

(d) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank entry has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling 2177851020.

(5) **SPECIAL CONTINGENCIES** : Tank relining, lining inspection and entry permit work in reference to manways/manholes must abide by section 175.500. Removing the manways on tank # 3 & 4 compartment tank split 12k/ 8k tripple washing the tank & vapor freeing tank . Xerxes representative will enter the tanks & repair. The tanks will be third party tested before putting back into service. **NOTE: This permit is only to allow entry in order to find the leak, the repair must be done under a separate upgrade permit. There must be a representative of the tank manufacturer present.**

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Seneca Companies, Inc.
4140 East 14th Street PO Box 3360
Des Moines, IA 50313

Contact Person: Keri Hankins
Phone: (816) 761-1270
Contractor Registration # IL598 Exp. 2/23/2020

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File