



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2034434  
Permit # 00532-2018UPG  
Request Rec'd 05/01/2018  
Amended Date  
Approval Date 5/1/2018 DS  
Permit Expires 5/14/2018

**Permit for Emergency Repair Request on 5/1/2018**

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Speedway, LLC P.O. Box 1500 Springfield, OH 455011500</p> <p>Contact: Eric Swaisgood (937) 863-6513</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Speedway #1412 19730 S. Harlem Ave. Frankfort, IL 604238692</p> <p>Contact: Gina Tremore (708) 479-8592</p>
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

*(a) Number and size of tanks being upgraded or repaired: (TK # 5) - 2,000*

*(b) Type of tanks:*

*(c) Type of piping: (TK # 5) Piping - Shear Valves*

*(d) Product to be stored in each tank: (TK # 5) - Kerosene*

*(e) Type of leak detection being used:*

*Tank:*

*Piping:*

*(f) Corrosion Protection being used:*

*Tank:*

*Piping:*

*(g) Spill containment devices, piping, and dispenser containment devices:*

*(h) Overfill prevention devices:*

*(i) Manway accessible at grade:*

**(4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

Upon visual inspection it was discovered that the shear valve at stem was leaking and needed to be replaced

We removed old shear valve under # 14 K-1 dispenser and replaced with new OPW 10BF-5725 shear valve

We anchored new shear to existing stabilizer.

We ran a Veeder Root .01 test and it passed

Owner Speedway will have US Tank out to perform 3rd party test. **NOTE: If there is no existing dispenser sump where piping is being broken on must be installed under a separate upgrade**


**permit**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

DRW Services, Inc.  
600 East Joe Orr Road  
Chicago Heights, IL 60411

Contact Person: Douglas Harmon  
Phone: (708) 758-3222  
Contractor Registration # IL194 Exp. 3/10/2020

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File