



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 1026881
Permit # 00553-2018UPG
Request Rec'd 05/04/2018
Amended Date
Approval Date 5/7/2018 DS
Permit Expires 11/8/2018

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Advanced Disposal Services Solid Waste Midwest, LLC 2230 Ernie Krueger Circle Waukegan, IL 60087 Contact: Mark Demming (815) 378-1679</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Advanced Disposal Services Solid Waste Midwest, LLC 8538 Highway 251 South Davis Junction, IL 61020 Contact: Drewey Overturf (815) 873-3201</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 4) - 10,000

(b) Type of tanks:

(c) Type of piping:

(d) Product to be stored in each tank: (TK # 4) - Diesel Fuel

(e) Type of leak detection being used:

Tank:

Piping:

(f) Corrosion Protection being used:

Tank:

Piping:

(g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 4) Spill Contain Device - Manhole Pre-manufactured Franklin Fueling Systems Defender 705 Double Wall

(h) Overfill prevention devices:

(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES : Replace overspill exisitng single wall with NEW double wall only

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Ceroni Piping Company
7770 Ceroni Road
Cherry Valley, IL 61016

Contact Person: Steve Ceroni
Phone: (815) 332-7777
Contractor Registration # IL2147 Exp. 6/25/2018

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File