



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
3127453152

Extended/Amended

FOR OFFICE USE ONLY

Facility # 2024044
Permit # 01424-2017REM
Request Rec'd 11/13/2017
Amended Date 11/16/2017 IL7
Approval Date 11/13/2017
Permit Expires 11/15/2018

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Alloy Property Company, LLC 2711 N. Haskell Ave., Suite 1700 Dallas, TX 75204 Contact: Laura Sims (214) 754-4800	(2) <u>FACILITY</u> - name and address where tanks are located: Alloy Property Company, LLC 2011 N. Southport Ave. (1509 W. Cortland St) Chicago, IL 60614 Contact: Todd Rusche (312) 202-3480
--	--

(3) REMOVAL OF TANKS:

- (a) *Number and size of tanks being removed: (TK # 1) - 100,000, (TK # 2) - 40,000, (TK # 3) - 125,000, (TK # 8, 9) - 5,000, (TK # 10) - 1,000*
- (b) *Description/location of piping being removed:*
- (c) *Product to be stored in each tank: (TK # 1, 2) - UNKNOWN, (TK # 3) - Heating Oil, (TK # 8, 9) - Gasoline, (TK # 10) - Unknown*
- (d) *Reason of tanks being removed:*
- (e) *If tank(s) is leaking, indicate IEMA incident number:*
- (f) *Date each tank was last used: (TK # 1, 3) - 9/1/1991, (TK # 2) - 6/1/1985, (TK # 8, 9, 10) - 12/31/1973*

- (4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) SPECIAL CONTINGENCIES :


Additional tanks found

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

RW Collins Company
7225 West 66th Street
Chicago, IL 60638

Contact Person: Alisa Anderson
Phone: (708) 458-6868
Contractor Registration # IL772 Exp. 2/9/2018

Sincerely,


Chief Engineer-Storage Tank Section

Raul Valdivia

cc: Storage Tank Safety Specialist
Division File

