



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2006974
Permit # 00655-2018UPG
Request Rec'd 05/25/2018
Amended Date
Approval Date 5/29/2018 DS
Permit Expires 11/29/2018

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>True North Energy, LLC 10346 Brecksville Road Brecksville, OH 44141</p> <p>Contact: Kurian Thottichirayil (440) 792-4200</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>True North Location 2096 17101 S. Harlem Tinley Park, IL 60477</p> <p>Contact: David P. Nye (330) 792-9999 Ext. 127</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3) - 10,000

(b) Type of tanks:

(c) Type of piping:

(d) Product to be stored in each tank: (TK # 1, 2, 3) - Gasoline

(e) Type of leak detection being used:

Tank:

Piping: (TK # 1, 2, 3) Leak Detect - Piping - Stand Alone Sensor Interstitial Monitoring Veeder Root non discriminating, (TK # 1, 2, 3) Leak Detect - Piping - Stand Alone Sensor Interstitial Monitoring Beaudreau 404 / 406 non-discriminating

(f) Corrosion Protection being used:

Tank:

Piping:

(g) Spill containment devices, piping, and dispenser containmnt devices:

(h) Overfill prevention devices:

(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES : Removing stand alone sensors from dispenser pans that are corroded and in disrepair. Per conversation with Fred Scheneller we were advised that this was allowable. We will allow as long as the sensors are hard wired to have the capability to shut down the submersible.


NOTE: All sensors installed after September 1, 2010 must immediately shut off the submersible pump supplying that line upon detection of a leak per 175.640 a) 2).

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

DRW Services, Inc.
600 East Joe Orr Road
Chicago Heights, IL 60411

Contact Person: Douglas Harmon
Phone: (708) 758-3222
Contractor Registration # IL194 Exp. 3/10/2020

Sincerely,

A handwritten signature in cursive script, reading "Daniel G. Starks", is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File