

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 2177851020

FOR OFFICE USE ONLY

Facility # 4040538 Permit # 00673-2018ENT Request Rec'd 05/31/2018 Amended Date Approval Date 5/31/2018 DS Permit Expires 11/30/2018

Permit for HOTWORK/ENTRY into Underground Storage Tank(s) for Petroleum and Hazardous Substances.

Permission to enter underground storage tank(s) is hereby granted. Such tank entry shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:

(2) <u>F</u>

(2) FACILITY - name and address where tanks are located:

Murphy Oil USA, Inc. 200 East Peach Street El Dorado, AR 71730 Murphy USA #6708 1206 Ave of Mid America Effingham, IL 62401

Contact: Aaron Grieb (870) 677-6116

Contact: Stacy McWhorter (217) 342-3780

(3) ENTRY OF TANKS:

- (a) Number and size of tanks being entered: (TK # 3) 14,000, (TK # 4) 7,000
- (b) Type of tanks:
- (c) Product to be stored in each tank: (TK # 3, 4) Gasoline
- (d) Manway accessible at grade:
- (4) The owner must notify this Office when completion of tank entry has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling 2177851020.
- (5) <u>SPECIAL CONTINGENCIES</u>: Tank relining lining inspection and entry permit work in reference to manways/manholes must abide by section 175.500. Primary tank # 3 & #4 has failed & leaking into the interstitial cavity. **Xerxes rep to enter and repair tank**

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Seneca Companies, Inc. 4140 East 14th Street PO Box 3360 Des Moines, IA 50313 Contact Person: Keri Hankins Phone: (816) 761-1270

Contractor Registration # IL598 Exp. 2/23/2020

Sincerely,

Daniel Starks

Daniel J. Starke

cc: Storage Tank Safety Specialist Division File