



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 7021632
Permit # 00726-2018UPG
Request Rec'd 06/11/2018
Amended Date
Approval Date 6/11/2018 DS
Permit Expires 12/11/2018

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Martin & Bayley, Inc. 1311 W. Main Street Carmi, IL 62821 Contact: Troy Dietz (618) 382-2334	(2) <u>FACILITY</u> - name and address where tanks are located: Hucks #177 601 West Poplar Street Harrisburg, IL 62946 Contact: Brittany Lovellette (618) 382-2334
--	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 5) - 10,000

(b) Type of tanks:

(c) Type of piping:

(d) Product to be stored in each tank: (TK # 5) - Gasoline

(e) Type of leak detection being used:

Tank:

Piping:

(f) Corrosion Protection being used:

Tank:

Piping:

(g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 5) Spill Contain Device - Manhole Pre-manufactured OPW 1C-3112D Edge Double Wall

(h) Overfill prevention devices: (TK # 5) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO-4010 Overfill drop tube

(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : We will saw cut and break concrete around the Plus tank riser. We will remove and dispose of broken concrete. Remove backfill around riser to top of the tank. Remove and replace riser pipe. Install new riser pipe, new spill containment bucket, and a new overfill protection drop tube. Replace backfill around riser, pour and finish concrete.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:


Jorgensen Petroleum Maintenance, Inc.

Contact Person: Matt Backer

921 Keck Avenue
Evansville, IN 47711

Phone: (812) 424-0014
Contractor Registration # IL2145 Exp. 6/19/2019

Sincerely,

A handwritten signature in cursive script that reads "Daniel H. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File