

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 2177851020

FOR OFFICE USE ONLY

Facility # 5036934 Permit # 00730-2018ABN Request Rec'd 06/11/2018 Amended Date Approval Date 6/12/2018 DS Permit Expires 12/12/2018

Permit for ABANDONMENT IN PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to abandon in place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity:

Havana Fuels, Inc.
Havana Fuels, Inc.
520 Laurel
Havana, IL 62644

Contact: Alex Alam (847) 917-6796

(2) FACILITY - name and address where tanks are located:
Havana Fuels, Inc.
520 Laurel Ave.
Havana, IL 62644

Contact: Donna Danley (847) 917-6796

(3) ABANDONMENT IN PLACE OF TANKS:

- (a) Number and size tanks being abandoned: (TK # 3) 12,000
- (b) Product stored in each tank: (TK # 3) Gasoline
- (c) Location of tanks being abandoned:
- (d) Location of piping being abandoned: We are removing a single gas dispenser from the truck islands at this location, and capping the pipe in an existing dispenser sump that will be covered. We will cap the other end of the pipe where it is teed from the sub pump to the truck island. By capping it, the line will no longer be charged when the sub pump is kicked on to feed the gas islands. It is not feasible to do soil borings for the pipe, since it lays on top of the tank it is piped to as well as the Diesel tank next to it. The piping runs in the same piping trench with the Diesel line still in use. That as well as conduits near pipe make it not a good plan to do soil borings. Contractor was given the ok to proceed without taking samples on 6/8/18. Please see attached waiver.
- (4) This permit is VOID if contamination is revealed during abandonment procedures or if tanks are not as indicated on your granted permit site plan. If contamination is revealed, this abandonment can continue only when the contaminated site section (2) of the certification on site condition has been submitted to our Office.

(5) <u>SPECIAL CONTINGENCIES</u>:

(6) The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(7) PERSON, FIRM OR COMPANY PERFORMING WORK:

Illinois Oil Marketing Equipment, Inc.

Contact Person: Chris Epkins

850 Brenkman Drive

Phone: (309) 347-1819

Pekin, IL 61554 Contractor Registration # IL1293 Exp. 2/4/2020

Sincerely,

Daniel Starks

Daniel J. Starks