



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Extended

FOR OFFICE USE ONLY

Facility # 2009149
Permit # 01567-2017UPG
Request Rec'd 12/14/2017
Amended Date
Approval Date 12/18/2017 DS
Permit Expires 12/19/2018

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>I K I Real Estate, LLC 22 West Butterfield Rd. Glen Ellyn, IL 60137</p> <p>Contact: Ibrahim Istanbuli (630) 915-7491</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Wings Mobil 22W070 West Butterfield Rd. Glen Ellyn, IL 60137</p> <p>Contact: Ibrahim Istanbuli (630) 915-4791</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 7) - 12,000, (TK # 8, 9) - 10,000, (TK # 10) - 8,000*
 - (b) Type of tanks:*
 - (c) Type of piping: (TK # 7, 8, 9, 10) Piping - Flexible Double Wall NUPI Smartflex, (TK # 7, 8, 9, 10) Piping - Submersible Sumps Bravo B-400 Series*
 - (d) Product to be stored in each tank: (TK # 7, 8, 9) - Gasoline, (TK # 10) - Diesel Fuel*
 - (e) Type of leak detection being used:*
 - Tank: (TK # 7, 8, 9, 10) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD*
 - Piping: (TK # 7, 8, 9, 10) Leak Detect - Piping - Electronic Pressurized Line Leak Detection Veeder Root TLS 350 PLLD leak sensors, (TK # 7, 8, 9, 10) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350*
 - (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
 - (g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 7, 8, 9, 10) Spill Contain Device - Manhole Pre-manufactured Franklin Fueling Systems Defender Series #7055*
 - (h) Overfill prevention devices: (TK # 7, 8, 9, 10) Overfill Prev Device - Overfill Drop Tube Valve OPW 61SOR, (TK # 7, 8, 9, 10) Overfill Prev Device - Overfill Alarm Veeder Root TLS 350*
 - (i) Manway accessible at grade:*
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES** : The existing DWFRP tanks are to remain. Installing new Bravo SWFRP sumps at the existing manways on all tanks, and Nupi SW HDPE dispenser sumps at all (4) island locations. Installing Nupi DW Semi-Rigid piping from tanks to new island locations, Nupi DW Semi-Rigid remote fill piping to parkway area near new vent rack, and Nupi SW Semi-Rigid vent / stage I remote piping from tanks to parkway area per plan. **Re-using the existing VR TLS 350 and ATG probes.** Installing (12) VR single float non-discriminating liquid sensors at sumps. Installing VR PLLD's at submersible pumps. Installing DW spill manholes at remote fill locations as


shown on plans. This work is to be done in early Spring 2018.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Performance Tank, Inc.
730 Creel Drive
Wood Dale, IL 60191

Contact Person: Tim Berg
Phone: (630) 860-9500
Contractor Registration # IL881 Exp. 10/27/2018

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File