



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 6021253
Permit # 00762-2018UPG
Request Rec'd 06/14/2018
Amended Date
Approval Date 6/19/2018 DS
Permit Expires 12/19/2018

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: C C Dillon Company 1342 Lonedell Road Arnold, MO 63010 Contact: Gene Wagstaff (314) 296-2700	(2) <u>FACILITY</u> - name and address where tanks are located: Race Way Gas & Food 8407 Collinsville Road Collinsville, IL 62234 Contact: Nick Badwan (618) 344-8197
--	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 1, 2) - 12,000, (TK # 3) - 6,000*

(b) *Type of tanks:*

(c) *Type of piping:*

(d) *Product to be stored in each tank: (TK # 1, 2) - Gasoline, (TK # 3) - Diesel Fuel*

(e) *Type of leak detection being used:*

Tank:

Piping: (TK # 1, 2, 3) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection Red Jacket FXIV

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containmnt devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Remove the existing electronic lline leak detectors and replace with mechanical line leak detectors due to obsoleted leak detection equipment and lack of parts availability to repair. **NOTE: Database shows that the site has Red Jacket FX1 as current leak detection already, but upon extensive review of the facility file the site has Incon TS-LLD, which was installed under permit 2317-98UPG.**

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:


Superior Acquisition LLC d/b/a Superior Equipment Company

Contact Person: Larry Scheller

7525-A Sussex
St. Louis, MO 63143

Phone: (314) 644-6000
Contractor Registration # IL002394 Exp. 2/26/2019

Sincerely,

A handwritten signature in cursive script that reads "Daniel H. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File