



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2005475
Permit # 00822-2018REM
Request Rec'd 07/02/2018
Amended Date
Approval Date 7/2/2018 DS
Permit Expires 1/2/2019

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Chicago Executive Airport 1020 South Plant Road Wheeling, IL 60090</p> <p>Contact: Andrew Wolanik (847) 537-1200</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Signature Flight Support 1100 S. Milwaukee Avenue Wheeling, IL 60090</p> <p>Contact: Tim Latendresse (847) 537-1200</p>
---	--

(3) **REMOVAL OF PIPING:**

- (a) *Description/location of piping being removed:*
- (b) *Which tank(s) are associated with the piping being removed: (TK # 17) - 20,000*
- (c) *Reason of piping being removed:*
- (d) *If piping is leaking, indicate IEMA incident number:*

(4) After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) **SPECIAL CONTINGENCIES** : Tank # 17 located by Hanger # 8, removal of one product line running from aboveground pump underground to transistion sump then to the above ground fueling cabinet located approximately 75 feet North of existing UST by taxi way. Removal of product line and abovegrond cabinet to allow expansion of parking for planes.

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

DRW Services, Inc.
600 East Joe Orr Road
Chicago Heights, IL 60411

Contact Person: Douglas Harmon
Phone: (708) 758-3222
Contractor Registration # IL194 Exp. 3/10/2020

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File