



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 6017351  
Permit # 00834-2018UPG  
Request Rec'd 07/03/2018  
Amended Date  
Approval Date 7/3/2018 DS  
Permit Expires 1/3/2019

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Martin & Bayley, Inc. 1311 W. Main Street Carmi, IL 62821  Contact: Troy Dietz (618) 382-2334	<b>(2) FACILITY</b> - name and address where tanks are located:  Hucks #351 1530 West Main Street Salem, IL 62881  Contact: Brian Yates (618) 548-8225
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 6) - 12,000, (TK # 7, 8) - 10,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 6, 7, 8) Piping - Flexible Double Wall OPW Flexworks, (TK # 6, 7, 8) Piping - Other submersible pump, (TK # 6, 7, 8) Piping - Shear Valves, (TK # 6, 7, 8) Piping - Valves Ball Valve, (TK # 6, 7, 8) Piping - Submersible Sumps OPW Fiberglass Single Wall*
- (d) *Product to be stored in each tank: (TK # 6, 7) - Gasoline, (TK # 8) - Diesel Fuel*
- (e) *Type of leak detection being used:*  
  
*Tank:*  
  
*Piping: (TK # 6, 7) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection Red Jacket FXIV, (TK # 6, 7, 8) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root 794380-208 Non-Discriminating Sump Sensor in all new dispenser and submersible sumps NOTE: Sensors must shut down the submersible supplying that line upon detection of a leak per 175.640 a) 2), (TK # 8) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection Red Jacket FXIDV*
- (f) *Corrosion Protection being used:*  
  
*Tank:*  
  
*Piping:*
- (g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 6, 7, 8) Spill Contain Device - Manhole Pre-manufactured OPW 1C-3132D Edge Double Wall*
- (h) *Overfill prevention devices: (TK # 6, 7, 8) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO-4000 overfill drop tube valve*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.


- (5) **SPECIAL CONTINGENCIES** : All dispensers are being replaced along with new piping from existing storage tanks as shown in site drawing

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Hinderliter Construction & Maint., Inc.  
3601 North St. Joseph Avenue  
Evansville, IN 47720

Contact Person: Mark Hinderliter  
Phone: (812) 425-4137  
Contractor Registration # IL646 Exp. 4/2/2020

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File