



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2025531  
Permit # 00844-2018REM  
Request Rec'd 07/06/2018  
Amended Date  
Approval Date 7/6/2018 FS  
Permit Expires 1/8/2019

**Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Lincolnwood Service, Inc. 713 Grey Ave. Evanston, IL 60202</p> <p>Contact: Bobby Hilliard (847) 869-1635</p>	<p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Lincolnwood Service, Inc. 2945 Central Street Evanston, IL 60201</p> <p>Contact: Robert Hilliard (847) 864-2002</p>
---	--

**(3) REMOVAL OF TANKS:**

- (a) *Number and size of tanks being removed: (TK # 1, 2, 3, 4) - 4,000, (TK # 5) - 500*
- (b) *Description/location of piping being removed:*
- (c) *Product to be stored in each tank: (TK # 1, 2, 3, 4) - Gasoline, (TK # 5) - Used Oil*
- (d) *Reason of tanks being removed: Condemned tanks. Removal will satisfy both pending NOV's.*
- (e) *If tank(s) is leaking, indicate IEMA incident number: 2018-0628*
- (f) *Date each tank was last used: (TK # 1, 2, 3, 4, 5) - 11/20/2013*

- (4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

**(5) SPECIAL CONTINGENCIES :**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Grand Slam Construction, LLC  
3805 Illinois Avenue  
St. Charles, IL 60174

Contact Person: Brian Morin  
Phone: (630) 377-0297 Ext. 102  
Contractor Registration # IL002419 Exp. 5/4/2019

Sincerely,

□  
Fred Schneller

cc: Storage Tank Safety Specialist  
Division File